

## **ACUA LANDFILL SOLAR RFP QUESTIONS:**

- 1. Will the ACUA entertain bids for ground systems located in areas other than the capped portion of the landfill?**

*No, the purpose of this RFP is for the installation of a solar photovoltaic system on the closed and capped portion of the ACUA's landfill only.*

- 2. Can we receive any landfill settlement data on the site to date or anticipated projects of such?**

*Information on the landfill is available on the ACUA website:*

*<http://www.acua.com/acua/rfps.aspx>*

*Additional information regarding settlement and other survey related data will be made available should recent survey work be completed prior to the RFP due date.*

- 3. Can we receive the electric usage and cost information from SJTA on the airport site?**

*The SJTA's annual electric demand is 1.5 MW with the entire campus (SJTA, FAA, National Guard) at 12 – 15 MW generating capacity needed.*

*The SJTA currently has a blended electricity rate of \$0.138 per kWh.*

- 4. When I try to open the answers from the site visit on the web, it looks like specs from a landfill project?**

*The information available on the ACUA's website is regarding the ACUA landfill closure plan, specifications from the landfill closure bid. These documents were requested to be made available during the solar project site visit.*