



MAIN METER VAULT. CONTRACTOR TO CORE VAULT AND TIE IN TO EXISTING PIPE STUB

PROPOSED LEACHATE FORCE MAIN TO DISCHARGE AT EXISTING LEACHATE STORAGE FACILITY
 4'0 HDPE SDR21 INSIDE
 6'0 HDPE SDR17 CONTAINMENT

INV. OUT=46.60
 MH M3
 MH P3
 MH S3
 GAS WELL
 INV. IN=26.93
 SLOPE = 0.0028
 INV. IN=28.73
 SLOPE = 0.01
 SLOPE = 0.01

| | | | | | | |
|--|---|------------------|---|---|-------------------|---------------------|
| SHEET TITLE: PROP. LEACHATE FORCE MAIN | ATLANTIC COUNTY UTILITIES AUTHORITY 6700 DELILAH ROAD EGG HARBOR TOWNSHIP, NJ 08234 | | PROJECT NAME: ACUA CELL #3 CONSTRUCTION | EUGENE L. PETITT PROFESSIONAL ENGINEER NJ LICENSE NO. GE28505 | DATE | REVISION |
| | DATE: 5-24-99 | SCALE: 1"=60' | | | DWG. NO: C3C-9 | CONTR.# SW-10-99 |
| | | | | | DRAWN G.P. | CHECK T.G. |